

**Radioactivity measurement for September 2019 was conducted.**

Result:

"No detection for cleaning water. Caesium was detected with External-Air Inlet Filter though, we are considering there is no influence on products (please refer to description below).

Note: Due to the delay in delivery of filter component in September, 3 locations filter planned in September was measured. (The result is indicating the maximum value out of 3 measurement.) Therefore, we publish the result of September.

Radioactivity Measurement (September, 2019)

Sample Category	Nuclide				Radiation Dose
	Caesium				
	I-131	Cs-134	Cs-137	Cs-136	
Unit	Bq/kg(L)	Bq/kg(L)	Bq/kg(L)	Bq/kg(L)	μSv/h
Tap Water	ND <sup>*1</sup>	ND <sup>*1</sup>	ND <sup>*1</sup>	-	-
External-Air Inlet Filter (Saitama Factory)	ND <sup>*2</sup> (Detection Limit : 13)	ND <sup>*2</sup> (Detection Limit : 14)	27 (Detection Limit : 17)	ND <sup>*2</sup> (Detection Limit : 14)	-

\*1) Tap water from Showa water filtering plant (Water at the water filtering plant exit):  
From the local government website(Period: 4th, Sep 2019 ~25th, Sep 2019) Detection Limit: around 0.5Bq/kg  
\*2) Not Detected

This time it was measurement of the External-Air Inlet Filter (Fig.1 ①) Detection of radioactive substances has stabilized at a low value in the past several years.(Table.1 "Transition of Radioactive Caesium Detection" below).

We have confirmed through the past measurement that the External-Air Inlet Filter traps most of the radioactive substance, and some portion which passed through the external filter will be trapped at Internal Circulatory Filter (Fig.1 ②). (Investigated in July 2011).

Regarding the products, there have been no detection in several times of the past measurement and we consider there is no influence.

Environmental radioactivity measure has temporarily increased after the accident though, it is considered that there have been no further increase up to the present. Therefore we consider that there is no influence to the environment inside the Clean Room and the product manufactured inside this Clean Room.




Table.1 Transition of Radioactive Caesium Detection

	May. 2011	Jan. 2012	Jul. 2012	Jan. 2013	Jul. 2013	Jan. 2014	Jul. 2014
Cs-134	250,000	2,100	500	140	83	62	130
Cs-137	270,000	2,700	740	290	190	170	340
	Feb. 2015	Aug. 2015	Jan. 2016	Apr. 2016	Sep.2016	Jan.2017	Mar.2017
Cs-134	54	22	ND	15	ND	ND	11
Cs-137	180	91	36	79	45	47	55
	Jul.2017	Sep. 2017	Jan. 2018	Mar. 2018	Jul. 2018	Sep.2018	Jan. 2019
Cs-134	ND	9	33	ND	ND	ND	ND
Cs-137	ND	74	360	56	ND	57	62
	Mar.2019	Jul.2019	Sep. 2019				
Cs-134	ND	ND	ND				
Cs-137	58	100	27				